



At least 2 inches of gravel-free earth shall be placed between lighting appurtenances and exposed underground utilities in conflict with lighting appurtenances.



ITEM	TYPE
LIGHTING STANDARD	AMERON CONCRETE OCTAGONAL POLE (ICI-ANCHOR BASE)
LAMP	GENERAL ELECTRIC
PULL BOX	BROOKS PRODUCT INC. NO. 3 1/2 OR EQUAL

CITY OF ARCADIA
DEVELOPMENT SERVICES DEPT. – ENGINEERING DIV.

805 - 1

RCE

DRAWN BY: AG/JC

SHEET 1 OF 1